

Institute for  
Thermal Turbomachinery  
and Machine Dynamics

Graz University of Technology  
Erzherzog-Johann-University

# Thermodynamic and Economic Investigation of an Improved **Graz Cycle** Power Plant for CO<sub>2</sub> Capture

Presentation at the  
ASME Turbo Expo 2004  
Vienna, Austria, June 14 - 17, 2004

**Wolfgang Sanz, Herbert Jericha, Mathias Moser and Franz Heitmeir**  
Institute for Thermal Turbomachinery and Machine Dynamics  
Graz University of Technology  
Austria



- **Kyoto Protocol demands the reduction of greenhouse gases**
- **CO<sub>2</sub> is responsible for about 60 % of the greenhouse effect**
- **About 30 % of the anthropogenic CO<sub>2</sub> emissions come from fossil fuel fired heat and power generation**
- **Possible measures:**
  - **efficiency improvement**
  - **use of fuels of lower carbon content (methane)**
  - **use of renewable (or nuclear) energy**
  - **development of advanced fossil fuel power plants enabling CO<sub>2</sub> capture**



- Fossil fuel **pre-combustion** decarbonization to produce pure hydrogen or hydrogen enriched fuel for a power cycle (e.g. steam reforming of methane)
- Power cycles with **post-combustion** CO<sub>2</sub> capture (membrane separation, chemical separation, ...)
- Chemical looping **combustion**: separate oxidation and reduction reactions for natural gas combustion leading to a CO<sub>2</sub>/H<sub>2</sub>O exhaust gas
- **Oxy-fuel power generation**: Internal combustion with pure oxygen and CO<sub>2</sub>/H<sub>2</sub>O as working fluid enabling CO<sub>2</sub> separation by condensation




- Combustion with nearly pure oxygen leads to an exhaust gas consisting largely of **CO<sub>2</sub>** and **H<sub>2</sub>O**
- + CO<sub>2</sub> can be **easily** separated by **condensation**, no need for very penalizing scrubbing
- + Very low NO<sub>x</sub> generation (only nitrogen from fuel)
- + Flexibility regarding fuel: natural gas, syngas from coal or biomass gasification, ...
- New equipment required
- Additional high costs of oxygen production
- + New cycles are possible with efficiencies higher than current air-based combined cycles (**Graz Cycle**, Matiant cycle, Water cycle,...)



- **1985:** presentation of a power cycle without any emission
  - H<sub>2</sub>/O<sub>2</sub> internally fired steam cycle, as integration of top Brayton cycle with steam and bottom Rankine cycle
  - efficiency 6 % - points higher than state-of-the art CC plants
- **1995:** Graz cycle adopted for the combustion of fossil fuels like methane (CH<sub>4</sub>)
  - cycle fluid is a mixture of H<sub>2</sub>O and CO<sub>2</sub>
  - thermal cycle efficiency: 64 %
- **2000:** thermodynamically optimized cycle for all kinds of fossil fuel gases (syngas, gas from gasification processes, ...)
- **2002/2003:** conceptual layout of turbomachinery relevant components of prototype Graz Cycle power plant




# Graz Cycle (ASME 2003, Atlanta)



- HTT High Temperature Turbine
- HRSG Heat Recovery Steam Generator
- LPT Low Pressure Turbine
- C1 - C3 CO<sub>2</sub> Compressors
- HPT High Pressure Turbine



# High Steam Content Graz Cycle (S-GC)





- Fuel: syngas from coal gasification with mole fractions: **50 % H<sub>2</sub>, 40 % CO, 10 % CO<sub>2</sub>**
- Complete stoichiometric combustion **at 40 bar** (pressure found in aircraft engines)
- Turbine inlet temperature in the range of high power stationary gas turbines: **1400° C**
- Turbine isentropic efficiency: **92 % (HPT 90 %)**
- Compressor isentropic efficiency: **88 %**
- Turbomachinery mechanical efficiency: **99 %**
- Generator electrical efficiency: **98.5 %**
- Cooling water temperature in condenser: **20° C**
- HRSG: cold side pressure loss: **5 bar**  
Pinch point: **5° C**
- CO<sub>2</sub> released at **1bar**





# Power Balance



|  | Graz Cycle  | S-Graz Cycle |
|--|-------------|--------------|
| HTT power [MW]                         | 91          | 127.5        |
| Total turbine power [MW]               | 111         | 150.4        |
| Total compression power [MW]           | 18.8        | 50.5         |
| <b>Net shaft power [MW]</b>            | <b>92.2</b> | <b>99.9</b>  |
| Total heat input [MW]                  | 143.4       | 143.4        |
| <b>Thermal cycle efficiency [%]</b>    | <b>64.3</b> | <b>69.6</b>  |
| <b>Electrical cycle efficiency [%]</b> | <b>63.3</b> | <b>68.6</b>  |



- Oxygen production (0.15 - 0.3): 0.25 kWh/kg (8 MW)  
Oxygen compression (1 to 40 bar, inter-cooled):  
0.125 kWh/kg (4 MW)  
**Efficiency: 60.3 %**
- Compression of separated CO<sub>2</sub> for liquefaction (1 to 100 bar, inter-cooled): 0.075 kWh/kg (3.7 MW)  
**Efficiency: 57.7 %**

## Methane firing:

Higher oxygen demand, less CO<sub>2</sub> emitted

**Respective efficiencies: 56.8 % / 55.3 %**

(steam reforming of methane ??)




- **Critical components**
  - **Combustion chamber**  
for stoichiometric combustion with O<sub>2</sub> and cooling with steam and CO<sub>2</sub>
  - **High temperature turbine HTT**  
unusual working fluid of 2/3 H<sub>2</sub>O and 1/3 CO<sub>2</sub>  
cooling with steam
- **Non-critical components**
  - **Low pressure turbine LPT**
  - **High pressure turbine HPT**
  - **CO<sub>2</sub> compressors**
  - **H<sub>2</sub>O/CO<sub>2</sub> compressors**
  - **Heat exchangers**



# Turbomachinery Arrangement S-Graz Cycle



- Different turbomachinery arrangement with 2 shafts
- First shaft: balance of compressor and turbine power
- Second shaft drives generator
- Turbo set with 3 different speeds  
23 000 rpm: HTT first stage + HPT + C2 WF-compressor  
12 000 rpm: HTT 2<sup>nd</sup>-4<sup>th</sup> stage + C1 WF-compressor + C4 CO<sub>2</sub>-compr.  
3 000 rpm: LPT + C4 CO<sub>2</sub>-compressor
- First layout for 100 MW plant: reasonable turbomachinery dimensions






# High Temperature Turbine HTT




- Pressure drop: 40 bar - 1 bar
- Enthalpy drop:  
**Graz Cycle: 965 kJ/kg** (similar to air-turbine exhaust gas) -> 3 stages  
**S-Graz Cycle: 1510 kJ/kg** -> 4 stages
- High rotational speeds to keep number of stages low
- Split into two overhang shafts to obtain optimal speeds

## Graz Cycle





## S-Graz Cycle





# GC HTT First Stage Design



**Mach number distribution  
at mid section**

- **Pressure drop: 40 bar - 10 bar**
- **Enthalpy drop: 450 kJ/kg**
- **Mach number up to 1.3 (800 m/s)**
- **Minimal twist of rotor blades due to stream line curvature**



## Investment costs

| Component   | Scale parameter           |                             | Specific costs |
|---|---------------------------|-----------------------------|----------------|
| <b>Reference Plant [13]</b>                         |                           |                             |                |
| Investment costs                                    | Electric power            | \$/kW <sub>el</sub>         | 414            |
| <b>S-Graz Cycle Plant</b>                           |                           |                             |                |
| Investment costs                                    | Electric power            | \$/kW <sub>el</sub>         | 414            |
| Air separation unit [14]                            | O <sub>2</sub> mass flow  | \$/ (kg O <sub>2</sub> /s)  | 1 500 000      |
| Other costs (Piping, CO <sub>2</sub> -Recirc.) [14] | CO <sub>2</sub> mass flow | \$/ (kg CO <sub>2</sub> /s) | 100 000        |
| CO <sub>2</sub> -Compression system [14]            | CO <sub>2</sub> mass flow | \$/ (kg CO <sub>2</sub> /s) | 450 000        |

- **yearly operating hours: 6500 hrs/yr**
- **capital charge rate: 15%/yr**
- **syngas is supplied at 3.5 ¢/kWh<sub>th</sub>**  
(alternatively methane firing at 1.3 ¢/ kWh<sub>th</sub>)



# Economical Analysis S-GC - II




COE ...  
Cost of  
Electricity

|   | Reference<br>plant [13] | S-Graz<br>Cycle | S-GC<br>+ CO <sub>2</sub> at<br>100 bar |
|---|-------------------------|-----------------|---|
| Plant capital costs [\$/kW <sub>el</sub> ]              | 414                     | 414             | 414                                     |
| Addit. capital costs [\$/kW <sub>el</sub> ]             |                         | 148             | 209                                     |
| CO <sub>2</sub> emitted [kg/kWh <sub>el</sub> ]         | 0.629                   | 0.0             | 0.0                                     |
| Net plant efficiency [%]                                | 56.2                    | 60.3            | 57.7                                    |
| COE for plant amort. [¢/kWh <sub>el</sub> ]             | 0.96                    | 1.3             | 1.44                                    |
| COE due to fuel [¢/kWh <sub>el</sub> ]                  | 6.22                    | 5.8             | 6.06                                    |
| COE due to O&M [¢/kWh <sub>el</sub> ]                   | 0.7                     | 0.8             | 0.8                                     |
| <b>Total COE [¢/kWh<sub>el</sub>]</b>                   | <b>7.88</b>             | <b>7.9</b>      | <b>8.30</b>                             |
| <b>Comparison</b>                                       |                         |                 |   |
| <b>Differential COE [¢/kWh<sub>el</sub>]</b>            |                         | <b>0.02</b>     | <b>0.42</b>                             |
| <b>Mitigation costs [\$/ton CO<sub>2</sub>]</b>         |                         | <b>0.3</b>      | <b>6.7</b>                              |
| <b>Mitigation costs methane [\$/ton CO<sub>2</sub>]</b> |                         | <b>13.0</b>     | <b>17.5</b>                             |






# Influence of Capital Charge Rate S-GC



**Syngas Firing:** MC varies between 1.5 and 12 \$/ton CO<sub>2</sub> for charge rate variation between 5 % and 25 % -> relatively small sensitivity



# Influence of Fuel Costs S-GC




**Syngas Firing: Higher fuel costs decrease the MC because of higher efficiency of S-GC**

**Fuel costs: 1-10 c/kWh -> MC: 9 – 3 \$/ton**

**Small influence on investment decision**



# Influence of Reference Plant Efficiency S-GC




**This parameter covers all influences on cycle efficiency**

**Reference plant of 60 %: MC 7 -> 13 \$/ton (26 \$/ton for methane)**



# Influence of Capital Costs S-GC



**Large uncertainty in cost estimation**

**ASU and CO2 separation: 50 % higher costs than reference plant**

**Double costs: MC = 15 \$/ton CO2, 3 x costs: MC = 30 \$/ton CO2**



- Presentation of an improved version of the Graz Cycle, the **High-Steam-Content S-Graz Cycle** as “zero-emission gas turbine cycle“ with oxy-fuel combustion and CO<sub>2</sub> retention
- Thermodynamic layout promises efficiencies up to **69 % (60 % if expenses of O<sub>2</sub> supply are considered)**
- Possible arrangement of turbomachines is presented showing feasibility
- Economic comparison with reference plant show competitiveness to state-of-the-art combined cycle power plants, especially for syngas firing
- Mitigation costs of about **7 \$/ton CO<sub>2</sub>** are promising under the prospect of a future CO<sub>2</sub> tax