



TURBO EXPO
Gas Turbine Technical Congress & Exposition
Presented by the International Gas Turbine Institute

ASME Turbo Expo 2010

June 14-18, 2010

Scottish Exhibition & Conference Centre • Glasgow, UK



**Institute for
Thermal Turbomaschinery
and Machine Dynamics**

**Graz University of Technology
Erzherzog-Johann-University**

FIRST GENERATION **GRAZ CYCLE POWER PLANT FOR NEAR-TERM DEPLOYMENT**

(ASME Paper GT2011-45135)

Wolfgang Sanz, Carl-W. Hustad* and Herbert Jericha

Institute for Thermal Turbomachinery and Machine Dynamics

Graz University of Technology, Austria


* CO2-Global LLC, Houston, Texas, U.S.A.



- To curb global warming and to maintain a certain CO₂ level in atmosphere **Carbon Capture and Storage (CCS)** has an important bridging function till renewables can take over
- Among CCS technologies **Oxy-Fuel Cycles** with internal combustion with pure oxygen are very promising
- A working fluid consisting mainly of **CO₂** and **H₂O** allows an easy separation by **condensation**
- Graz University of Technology has worked since 1995 on the **Graz Cycle**, an oxy-fuel cycle of highest efficiency, presenting thermodynamic studies and turbomachinery layout



Graz Cycle (ASME 2005)






- Electrical cycle efficiency for **methane** firing:
Efficiency: 64.6 % (same for syngas firing)
- Oxygen production (0.15 - 0.3): 0.25 kWh/kg
Oxygen compression (2.38 to 40 bar, inter-cooled): 325 kJ/kg
Efficiency: 54.8 %
- Compression of separated CO₂ for liquefaction (1 to 100 bar, inter-cooled): 270 kJ/kg (3.7 MW)
Efficiency: 52.7 %



- **Significant development effort and further research is needed**
- **Quick alternative: use of commercially available plant equipment for a near-term demonstration plant**
-> example of Clean Energy Systems, Inc. (CES)
- **CES: prototype oxyfuel power plant in California since 2005**





CES Cycle (ASME 2010)



Cycle Fluid
79 % H₂O
21 % CO₂


taken from
GT2010-23001



- Main difference: recycle compressor in the Graz Cycle which is technically more challenging but leads to higher efficiency
- Main components have similar engineering specifications
- Both cycles can benefit from related R&D done for each cycle



- Considerable experience with GG of 20 and 170 MWth
- Kimberlina Power Plant (KPP), CA: 20 MWth GG + a small steam turbine -> fully proven proof-of-concept
- Current implementation of a **re-engineered GE J79 turbine as a high-temperature turbine expander**:
 - removal of 17-stage axial compressor
 - thrust bearing system added
 - inflow through a volute manifold
 - approximately 32 MW (shaft) power output
 - additional single-stage turbine providing 11 MW
- Further work for a next generation oxy-turbine based on Siemens SGT-900 (funded by DOE)




taken from
GT2010-23001



- **Question:**
What can be achieved, technically as well as economically, if J79 is installed in a first-generation Graz Cycle Plant?
- **Presentation of a first generation Graz Cycle plant with a simplified flow scheme and modest cycle data based on the J79 turbine expander**
- **Discussion of power data and efficiencies for a pilot plant**
- **An economic analysis for niche market application**


- **Combination of J79 main and exhaust turbine will be employed in KPP as an IP turbine.**
- **Working fluid will be provided by the 170 MWth CES GG**
- **Similar power output at inlet conditions of 760°C/11.6 bar, compared with 927°C / 12.3 bar originally.**
- **No need for blade cooling**






- At a suitable location where revenues using CO₂ for enhanced oil recovery (EOR) can be obtained
- Benefits using a mixture of NG (5%) and available Reservoir Gas (RG) that has up to 85% CO₂ content
- Heating value: HHV of about 265 Btu/scf (5.75 MJ/kg/ LHV 5.25 MJ/kg)

GAS SPEC mol-%	Res Gas	Pipeline NG	Fuel Gas
CH ₄	7.50%	93.9 %	11.8 %
C ₂ H ₆	2.50%	3.20%	2.54%
C ₃ H ₈	1.50%	0.70%	1.46%
C ₄ +	2.00%	0.30%	1.92%
N ₂	1.50%	0.90%	1.47%
CO ₂	85.0 %	1.00%	80.8 %
HHV (Btu/scf)	224	1033	265



- The condenser operates at atmospheric conditions
- Lower cycle peak pressure -> only C1 compressor



- Relatively low steam superheating
- Cooling before C1 increases overall efficiency



Turbine Operating Conditions

Operating Parameters	i) CES- J79: NG	ii) GC- B-J79: FG	iii) GC- AD-J79: FG
Mass flow [kg/s]	62.7	77.9	74.1
Inlet pressure [bar]	11.6	11.6	12.3
Inlet temperature [°C]	760	760	815
Speed [rpm]	7460	7460	6890
Main Turbine [MW]	32.4	32.6	33.0
Exhaust Turbine [MW]	10.8	10.9	10.7
% Composition (H ₂ O/CO ₂)	85/15	54/45	51/48
Inlet Volume [m ³ /s]	23.4	23.3	21.5
Intermediary Vol. [m ³ /s]	95.0	96.1	93.9
Exit Vol. [m ³ /s]	163	166	162.7
Spec. Enthalpy drop [kJ/kg]	710	576	607
Main Turbine Exit Temp. [°C]	500	514	552
Exh. Turbine Exit Temp. [°C]	409	426	463



CES Cycle	Fuel Gas is as shown in Table 1 column 3	GC-B-J79 (760°C/ 11.6 bar)	GC-AD- J79 (815°C/ 12.3 bar)
170 MWth	Total Heat Input (HHV) [MW]	65.3	62.6
43.2 MW	Total Turbine Power [MW]	43.5	43.6
	Compressor Power [MW]	23.5	22.5
43.2 MW	Net shaft power [MW]	20.0	21.1
	Thermal cycle efficiency [%] ⁽¹⁾	30.6	33.7
	Auxiliary Losses [MW] ⁽²⁾	0.6	0.6
	Electrical cycle efficiency [%] ⁽³⁾	29.2	32.2
	Power for ASU [MW] ⁽⁴⁾ (0.34 kWh/kg)	5.9	5.7
	Net Power Output [MW_e]	13.2	14.5
	Net Efficiency (HHV) [%] ⁽⁵⁾	20.2	23.2
	Net Efficiency (LHV) [%] ⁽⁵⁾	22.2	25.4



- **Deployment of a Basic Graz Cycle plant in a niche market with revenue from multiple product streams: Permian Basin or onshore along the Gulf Coast with enhanced oil recovery (EOR)**
- **Opportunity for using CO₂ as well as N₂ as injectant gas into the same or two adjacent oil zones at different depths**
- **Costs are appropriate for the Gulf Coast area as of 3Q-2010**



Graz Cycle - Basic Reservoir Gas with 5% NG	
INVESTMENT SUMMARY	\$mill.
Power Plant Capital Cost	41.54
Air Separation Unit Cost	44.05
Total CO2 Plant Capital Cost	85.6 \$mill.
Development Costs	2.77
Pre-FEED + Contingency	1.08
Interest During Construction	4.49
Govt. Grant Support	0.00
TOTAL PROJECT COST	93.9 \$mill.

- **Base case scenario without plant compression equipment, but selling of injectant gas**
- **Specific power plant costs: US-\$ 3147/kW (13.2 MWe **net** power)**
- **ASU: 414 tpd O2 -> US-\$46.5/ tpd**



PLANT CAPACITY SUMMARY	
Power Output	13.2 MWe
Efficiency (HHV) 15,405 Btu/kWh	20.2 %HHV
Availability	92.0 %
Annual Production Hours	8,065 hrs
Annual Electrical Output	0.106 TWh
Annual CO2 Output	0.394 mt/yr
Annual N2 Output	0.454 mt/yr
Annual H2O Output	0.068 mt/yr

- **Combustion process yields 68,000 t/yr (~54,000 US gall/day) of industrial-quality de-ionized water**



FINANCIAL ASSUMPTIONS	
Interest Rate	7.5%
Equity Percent	30%
Debt Term	12 yrs
Project Duration	15 yrs
Construction Duration	1.5 yrs
Business Tax Rate	34.0%
Discount Rate	15.0%

- **70% debt financing**
- **Project duration of 15 years: assumption that adjacent fields will help extend power plant operation beyond the 5 to 8 years typical for tertiary oil recovery floods**



REVENUE ASSUMPTIONS		
Electricity Tarrif	60.0	\$/MWh
Fuel Gas Cost	3.59	\$/MMBtu
CO2 Sales Price	19.01	\$/tonne
CO2 Credit Price	0.00	\$/tonne
Oxygen Cost	0.00	\$/tonne
N2 Sales Price	14.93	\$/tonne
H2O Sales Price	0.00	\$/tonne

- **Fuel cost: \$3.59 /MMBtu (HHV) based on \$4.50 /MMBtu (HHV) for NG**
- **Electricity tariff: typical market spread \$55 to \$95 /MWh**
- **CO2 sales price: \$1.00 /Mcf (\$19.0 per tonne) uncompressed**
- **N2 sale is not standard practice, but does occur
\$0.50 /Mcf (\$14.9 per tonne) uncompressed has commercial value when
oil remains above \$80 /bbl**
- **No credits for CO2 retention and possible H2O sale**
- **O2 costs are already considered**



Net Operating Income

ANNUAL RESULTS	\$mill.
Electricity Sales	6.39
CO2 Sales	7.48
Emission Credits	0.00
N2 Sales	6.78
Steam Sales	0.00
H2O Sales	0.00
Gross Revenues	20.65 \$mill.
Oxygen Costs	0.00
Fuel Gas Costs	6.46
O&M Costs	0.83
Operating Costs	7.29
Net Operating Income	13.36 \$mill.

- **Gross revenue is evenly distributed between sales of electricity, CO2 and N2**
- **No income from sales of produced steam /water nor emission credits (e.g. NOx, sulfur or CO2 for zero emission power)**



Graz Cycle - Basic Reservoir Gas with 5% NG		
FINANCIAL SUMMARY		Project Analysis
Startup Date:	Project Life:	
2014 - Q2	15 yrs	
Total Project Investment		93.9 \$mill.
Net Annual Operating Income		13.4 \$mill.
Investment Return	Unlevered	14.5% IRR
	Levered	21.8% IRR

- Net annual income suggests a payback period of 7 years
- IRR is compatible with financial market expectations
- Multiple revenue streams reduce sensitivity to cost escalation in one area thereby balancing economic risk
- IRR identical for Advanced Graz Cycle despite higher efficiency



- To achieve near-term development of a GC oxyfuel plant for CCS utilization of existing hardware is proposed
- Based on CES experience with GE J79 turbine expander a “near-term” Graz Cycle plant is presented
- Efficiencies of 20 to 23 % and power output of 13.2 to 14.5 MW can be expected
- For economic evaluation a unique market location (EOR) where power, CO₂ and N₂ are needed at volumes comparable with the proposed power plant (multiple revenue streams)
- Economic analysis gives a payback period of 7 yrs and IRR at financial market expectations
- Multiple product streams make the project more robust.
- **This strategy can enable proof-of-concept demonstration of oxyfuel technology for CCS at acceptable return on invested capital**